



## OFFICE OF THE SUPERINTENDING ENGINEER

NATIONAL INSTITUTE OF TECHNOLOGY KARNATAKA, SURATHKAL

SRINIVASNAGAR P.O. – 575 025, MANGALURU (D.K)

E mail: [nitk.re@gmail.com](mailto:nitk.re@gmail.com)

Phone: (0824) 2473028

**No. NIQ/ PUMP / 2023-24/Stores**

**Date: 06-10-2023**

### **NOTICE INVITING QUOTATIONS – 2<sup>nd</sup> Call**

The National Institute of Technology Karnataka, Surathkal (in short - NITK, Surathkal or Institute) is an autonomous Institute of the Govt. Of India [under the Ministry of Education] imparting technical and science education. The Institute intends to **“Supplying of 5 HP Submersible Pump set to English Medium School sump tank and another Guest house sump tank., 15HP Monoblock pump for Pump house at NITK”**. The details of work listed on the sheet enclosed. In this connection, sealed quotations are invited by the undersigned subject to the terms and conditions enumerated here under from the Contractor/ agencies so as to reach this office on or before **18-10-2023** by **3:30 PM**. The quotations shall be opened on the same day if possible.

#### **Terms and conditions:**

1. The intending bidder shall quote his rates in the ‘Quotation Format’ enclosed here with either in his letter head or using the same format. He / She shall sign each page with seal of the firm. Envelope super scripted as Quotation for **“Supplying of 5 HP Submersible Pump set to English Medium School sump tank and another Guest house sump tank., 15HP Monoblock pump for Pump house at NITK”**. and addressed to as “The Superintending Engineer, NITK, Surathkal, Post Srinivasnagar, Mangaluru – 575025”
2. The GST registration number and the PAN number of the bidder shall be mentioned in the quotation. Quotation without this information will not be accepted.
3. Quotation may be dropped in the Tender Box kept in the office or may be sent by post/ courier. It is the responsibility of the bidder to make sure that the quotation is delivered in time. The quotations received after the due date will not be entertained. The rate quoted shall be valid for 90 days for its acceptance.
4. The bidder shall specify the make of material for which the rate is offered by him. Complete technical details of the quoted item should be submitted along with the quotation.
5. Freight of Rate [F.O.R] – NITK, Surathkal.
6. **The quotation/ bid shall be accepted depending on the total lowest amount quoted for item. The bidder who quoted total lowest amount will supply the materials.**
7. The work should be supplying the item within 15 days from the date of confirmation of acceptance of the quotation.
8. Tenderer shall refer the details, specifications enclosed separately. The materials should be strictly as per the specification specified, without which the materials will be rejected.
9. No advance payment will be made. The payment shall be made within 30 days from the date of completion of work.

No interest will be paid for delayed payments if any.

10. The rate quoted should be firm. No claim for enhancement of rate is admissible after opening of the Quotations.
11. The Institute reserves the right to cancel the quotations accept any quotation other than the lowest or modify the quantity of the materials at any time after/ before opening of the quotation. The bidder shall have no claim in this regard.
12. Terms and conditions stipulated in this notice inviting conditions are binding on the bidder.

Yours Faithfully,

Sd/-  
Superintending Engineer  
NITK, Surathkal

Name and Address of the Bidder:

Contact No:

GST registration number:

PAN number: -

Date:

**QUOTATION**

To

The Superintending Engineer,  
Office of the Resident Engineer,  
N.I.T.K., Surathkal.

Sl. No	Description of the items	Quantity	Rate without tax in Rs / each	GST	Amount with tax in Rs.
1	<b>5 HP submersible pump specifications:</b> <b>Make: Kirloskar / Crompton Greaves / Texmo</b> Rated Power: 5HP 3.7kw Type of Insulation: B Type Type of Connection: DOL Type Impeller material: Stainless steel, Cast Iron, Bronze Motor body: Stainless steel, Cast Iron, Delivery casing: Cast Iron Shaft : Stainless Steel Suction & Delevery pipe size: 50mm (Inlet) & 40mm (Outlet) Required Head & Discharge: 3.5 LPS @ 40 Mtrs. Warranty Period: Minimum One Year	2 Nos			
2	<b>15 HP Monoblock pump specifications:</b> <b>Make: Kirloskar / Crompton Greaves / Texmo</b> Rated Power: 15HP 11kw Type of Insulation: B/F Type Type of Connection: Star Delta Type Impeller material(Dual Impeller): Stainless steel, Cast Iron, Bronze Motor body: Cast Iron, Delivery casing: Cast Iron Shaft: Stainless Steel/ Carbon steel Suction & Delevery pipe size: 65mm (Inlet) & 65mm (Outlet) Required Head & Discharge: 3.2 LPS @ 64 Mtrs. Type of sealing: Gland packed / Mechanical seal Warranty Period: Minimum One Year	1 No			
	<b>Grand Total Amount</b>				

Seal and signature of the Bidder

